

SISTEMA-TESTE - VERIFICACAO DAS CONDICAOES DE REGIME PERMANENTE

dimsist	9	3	9	0	0	0		
tipfalt	0							
tempo	0.	.01	.01	5.	.01	.01	2.0	
falta	1	6	4	0.	.25	.25		
rlgmlp	0	0	0.	0.	0	0	0	0
barras	1	1.04000	.00000	.71641	.27046	1 1.00	.00000	.00000
	2	1.02500	9.28001	1.63000	.06654	1 1.00	.00000	.00000
	3	1.02500	4.66475	.85000	-.10860	1 1.00	.00000	.00000
	4	1.02579	-2.21679	.00000	.00000	1 1.00	.00000	.00000
	5	.99563	-3.98880	.00000	.00000	1 1.00	1.25000	.50000
	6	1.01265	-3.68740	.00000	.00000	1 1.00	.90000	.30000
	7	1.02577	3.71970	.00000	.00000	1 1.00	.00000	.00000
	8	1.01588	.72754	.00000	.00000	1 1.00	1.00000	.35000
	9	1.03235	1.96672	.00000	.00000	1 1.00	.00000	.00000
linhas	1	1	4	.00000	.05760		.00000	
	2	2	7	.00000	.06250		.00000	
	3	3	9	.00000	.05860		.00000	
	4	4	5	.01000	.08500		.17600	
	5	4	6	.01700	.09200		.15800	
	6	5	7	.03200	.16100		.30600	
	7	6	9	.03900	.17000		.35800	
	8	7	8	.00850	.07200		.14900	
	9	8	9	.01190	.10080		.20900	
maq.1	1	1	0	0.	.0800	.1000	.1550	25.00
	0.	1.	1.	9.00	0.	0.	0.	
maq2	2	1	0	0.	.1200	.9000	.9000	6.9
	0.	1.	1.	6.00	0.	0.	0.	
maq3	3	1	0	0.	.1813	1.2578	1.3200	3.00
	0.	1.	1.	6.50	0.	0.	0.	